

Village of Gibsonburg

2025 Drinking Water Consumer Confidence Report

Mayor: Steve Fought
Office: 419-637-7166

Village Administrator:
Office: 419-637-2634

Operators: Brad Hershey & Rob Helle
Office: 419-637-7417

Utility Clerk: Jen Cox
Office: 419-637-2323

Village Office:
526 N. Webster Street
Gibsonburg, Ohio 43431

Village of Gibsonburg Water Treatment



The Gibsonburg Water Treatment Plant has prepared the following report to provide information to you, the consumer, on the quality of our drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts.

Introduction

For this past year the high service pumps water plant pumped on average 238,492 gallons per day, while having a range of 171,880 gallons per day to 305,620 gallons per day in a 24-hour period. Total high service pumpage for 2025 was 87,049,490 gallons. Our 5 wells daily average was 294,300 gallons with a total of 107,419,200 gallons for 2025. In total the storage capacity for the distribution system is 700,000 gallons when we are at full capacity. Regular hours at the plant are 7 a.m. – 3:00 p.m., Monday through Friday. Village office hours are 8:00 a.m. – 4 p.m., Monday through Friday.

Village Web Site: www.gibsonburgohio.org

Facebook: www.facebook.com/gibsonburgohio

Source Water Information

The Gibsonburg Water Plant receives its drinking water from five deep limestone wells located at the south and southeast sections of town. In recent years, Ohio EPA completed a study of the Village of Gibsonburg's source of drinking water, to identify potential contaminant sources and provide guidance on protecting the drinking water source. According to this study, the aquifer that supplies the Village has a high susceptibility to contamination. This determination is based on the presence of a relatively thin protective layer of clay overlying the aquifer; shallow depth (less than 10 feet below ground surface) of the aquifer; the well is located in a sensitive potential karst area; presence of significant potential contaminant sources in the protection area; and the presence of manmade contaminants in raw water. Benzene, cis-1,2-Dichloroethylene, tetrachloroethylene and trichloroethylene were detected in the ground water at levels of concern from February, 1991 to 2010 when the Village removed a contaminated well from production. The Village of Gibsonburg continues to sample for volatile organic compounds quarterly. If you would like more information on our source water or would like a copy of the report, please contact the village and one will be provided.

What are sources of contamination to drinking water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; (E) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, USEPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Federal Environmental Protection Agency's Safe Drinking Water Hotline (1- 800-426-4791).

Special Precautions

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

About Your Drinking Water

The EPA requires regular sampling to ensure drinking water safety. The Gibsonburg Water Department conducted sampling for bacteria; nitrate; disinfection byproducts; inorganic; volatile organic; and lead and copper during 2025. Many of the contaminants were not detected in the Village of Gibsonburg’s water supply. The Ohio EPA requires us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, may be more than one year old. To assist you, the year of testing has been indicated in or below the chart in years prior to 2025.

How do I participate in decisions concerning my drinking water?

Public participation and comment are encouraged at regular meetings of the Gibsonburg Village Council which meets at 6:00 PM on the first and third Thursdays of each month at the Gibsonburg Town Hall. For more information on your drinking water or additional copies of this report, you may contact Brad Hershey at 419-637-7417. Paper copies are available at town hall upon request. This report is also available on the Village of Gibsonburg website at www.gibsonburgohio.org under Village Departments, Water Department, and Drinking Water Quality Report. A list of recent reports can be found there. In 2025 we had an unconditioned license to operate our water system. Listed below, is information on those contaminants that were found in the Village of Gibsonburg’s drinking water. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. If you have any questions about these results, please contact town hall during regular business hours and your questions will be answered in a timely manner.

TABLE OF DETECTED CONTAMINANTS 2025

Contaminants (Units)	MCLG	MCL	Level Found	Range of Detections	Violation	Sample Year	Typical Source of Contaminants
Microbiological							
Total Coliform Bacteria	0	1	0	0	No	2025	Naturally present in the environment.
Disinfectant and Disinfectant By-Products							
Total Chlorine (ppm)	MRDLG = 4	MRDL = 4	1.32	1.18 - 1.45	No	2025	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	N/A	60	0	0	No	2025	By-product of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	N/A	80	19.35	18.1 -20.6	No	2025	By-product of drinking water disinfection
Inorganic Contaminants							
Fluoride (ppm)	4	4	1.46	1.46	No	2025	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Barium (ppb)	2	2	0.0559	0.0559	No	2025	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits

Cyanide, Free (ppb)	2	2	0.763	0.763	No	2025	Typically originates from industrial wastewater discharges, landfill leeches
Benzene (ppb)	0	5	0.06	0 - 0.09	No	2025	Discharge from factories; leaching from gas storage tanks and landfills
CIS 1,2 Dichloroethylene (ppb)	70	70	0.1	0 - 0.2	No	2025	Discharge from industrial chemical factories
Toluene (ppb)	100	100	0.035	0.05 - 0.09	No	2025	Discharge from petroleum factories.
Ethylbenzene (ppb)	700	700	0.075	0 - 0.2	No	2025	Discharge from industrial chemical factories, and leaking underground fuel storage tanks.
Trichloroethylene (ppb)	0	5	0.025	0.2-0.3	No	2025	Discharge from metal degreasing sites another other factories.
Radioactive Contaminants							
Combined Radium 226/228	0	5	1.07-1.07	0	No	2022	Erosion of Natural Deposits
Gross Alpha excluding radon and uranium	0	15	4.6-4.6	0	No	2022	Erosion of Natural Deposits
Lead and Copper	Action Level (AL)	MCLG	# Sites Over AL	90th Percentile	Violation	Sample Year	Likely Source of Contamination
Lead (ppb)	15 ppb	0 ppb	0	1.8	No	2025	Corrosion of household plumbing systems; erosion of natural deposits
	0 out of 10 samples were found to have lead levels in excess of the lead action level of 15 ppb.						
Copper (ppm)	1.3 ppm	1.3 ppm	0	0.119	No	2025	Erosions of natural deposits;Corrosions of household plumbing systems
	0 out of 10 samples were found to have copper levels in excess of the copper action level of 1.3 ppm.						

Terms and Definitions

In this report, you may find terms and abbreviations that might not be familiar to you. For better understanding of these terms, the following definitions have been provided:

Parts per million (ppm) or Milligrams per liter (mg/L) – are units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days.

Parts per billion (ppb) or Micrograms per liter (ug/L) – are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years.

Picocurie per liter (pCi/L) – A common measure of radioactivity.

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

The “<” symbol: A symbol which means less than. A result of <5 means that the lowest level that could be detected was 5 and the contaminant in that sample was not detected.

¹**Lead Educational Information** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Gibsonburg Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 800-426-4791 or at <http://www.epa.gov/safewater/lead>

Lead Service Line Information

Per the lead and copper rules, public water systems were required to develop and maintain a service line inventory. A service line is the underground pipe that supplies your home or building with water. To view the service line inventory, which lists the material type(s) for your location, you can visit the following link:

https://gibsonburgohio.org/lead-service-line-inventory_2025/

To schedule an in-home service line inspection please call town hall at (419) 637-2323 or e-mail b.hershey@gibsonburgohio.org

Social Media

Village Web Site: www.gibsonburgohio.org

Facebook: www.facebook.com/gibsonburgohio

In 2025 Gibsonburg Public Water System had an unconditioned license to operate our water system



**Village of Gibsonburg
526 N. Webster Street
Gibsonburg, Ohio 43431
Phone: 419-637-2323**